

# 600V Generator Cable

## UL Type TC / TC-ER-JP



### APPLICATION:

Multi-conductor all in one cable for connecting a 17kW-26kW generator to a transfer switch. JP (Joist Pull) rated per NEC 336.10(9). UL listed as Type TC-ER-JP for applications not to exceed 600V.

### CONDUCTORS:

- Element 1: Annealed bare copper Class C
- Element 2: Annealed bare copper Class K
- Element 3: Annealed bare copper Class C

### INSULATION:

- Element 1, 2 & 3: Polyvinylchloride (PVC) & Nylon

### ASSEMBLY:

- All 3 Elements or Conductors are cabled together with Non-Hygroscopic Polypropylene fillers as required for a circular cross-section with a clear mylar binder tape and jacketed

### JACKET:

- Black sunlight & flame resistant and direct burial approved PVC with ripcord rated 90°C wet or dry per UL 1277

### COLOR CODE:

- Element 1: Black, Red, White
- Element 2: Black, Red, Yellow, Yellow/Black, Blue, White, White/Blue, Purple, Purple/Black
- Element 3: Green Ground

### STANDARDS:

- UL Listed as TC-ER-JP per UL Standard 1277
- Rated 90°C wet or dry to meet UL 83 for THHN/THWN
- Meets cold bend test at -40°C
- ICEA S-73-532. ICEA S-95-658, where applicable
- Meets UL 1581 & 1202 (FT-4) 70,000 BTU/HR & ICEA T-29-520 210,000 BTU/HR requirements
- REACH compliant per Regulation (EC) No 1907/2006 (235) Updated June 14, 2023
- Cable is suitable for use in Class I Division 2 hazardous locations
- Element 1 & 2 conductors pass UL VW-1 flame test, rated THWN/VW-1
- ASTM B3, B8, B174, B787
- UL approved for Direct Burial & Sunlight Resistant Applications

Part Number (Ampacity*, Rating**)	Section	Conductor Size	No. of Conductors	No. of Strands	Insulation Thickness		Nylon Thickness		Jacket Thickness		Overall Diameter	Net Weight
		AWG			Inches	mm	Inches	mm	Inches	mm	Inches	lbs/kft
2-03TCG/18-06-VN (115 amps, 26kW)	Element 1	2	3	19	0.040	1.02	0.007	0.18	BK, RD, WT			
	Element 2	18	6	16	0.015	0.38	0.005	0.13	BK, RD, YL, YL/BK, BL, WT			
	Element 3	6	1	19	0.030	0.76	0.005	0.13	Green Ground			
	Overall								0.080	2.03	1.013	1049
2-03TCG/18-08-VN (115 amps, 26kW)	Element 1	2	3	19	0.040	1.02	0.007	0.18	BK, RD, WT			
	Element 2	18	8	16	0.015	0.38	0.005	0.13	BK, RD, YL, YL/BK, BL, WT, WT/BL, PU			
	Element 3	6	1	19	0.030	0.76	0.005	0.13	Green Ground			
	Overall								0.080	2.03	1.013	1060
2-03TCG/18-09-VN (115 amps, 26kW)	Element 1	2	3	19	0.040	1.02	0.007	0.18	BK, RD, WT			
	Element 2	18	9	16	0.015	0.38	0.005	0.13	BK, RD, YL, YL/BK, BL, WT, WT/BL, PU, PU/BK			
	Element 3	6	1	19	0.030	0.76	0.005	0.13	Green Ground			
	Overall								0.080	2.03	1.013	1070

All values are nominal and subject to correction.

\*Ampacity according to NEC 310.15(B)(16) @30°C THWN 75°C insulated wires.

\*\*Installations shall follow NEC, applicable correcting factors shall be considered when conditions vary.



1-800-945-5542  
www.PriorityWire.com



# 600V Generator Cable UL Type TC / TC-ER-JP



Part Number (Ampacity*, Rating**)	Section	Conductor Size	No. of Conductors	No. of Strands	Insulation Thickness		Nylon Thickness		Jacket Thickness		Overall Diameter	Net Weight
		AWG			Inches	mm	Inches	mm	Inches	mm	Inches	lbs/kft
3-03TCG/18-09-VN (100 amps, 17kW-24kW)	Element 1	3	3	19	0.040	1.02	0.007	0.18	BK, RD, WT			
	Element 2	18	8	16	0.015	0.38	0.005	0.13	BK, RD, YL, YL/BK, BL, WT, WT/BL, PU, PU/BK			
	Element 3	8	1	19	0.030	0.76	0.005	0.13	Green Ground			
	Overall								0.080	2.03	0.983	903

All values are nominal and subject to correction.

\*Ampacity according to NEC 310.15(B)(16) @30°C THWN 75°C insulated wires.

\*\*Installations shall follow NEC, applicable correcting factors shall be considered when conditions vary.



1-800-945-5542  
www.PriorityWire.com

